



Product Service

# Compliance Document

No. D 093675 0034 Rev. 03

**Holder of Certificate:** **GCL System Integration Technology Co., Ltd.**  
Jianghai Economic Zone, Nanqiao Town  
Fengxian District  
201406 Shanghai  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

**Model(s):** GCL-M12/60Hxxx (xxx=580-610 in step of 5W)  
GCL-M12/66Hxxx (xxx=635-675 in step of 5W)  
GCL-M10/72Hxxx (xxx=525-555 in step of 5W)  
GCL-M10/60Hxxx (xxx=440-460 in step of 5W)  
GCL-M10/54Hxxx (xxx=395-415 in step of 5W)  
GCL-NT10/72Hxxx (xxx=550-575 in step of 5W)  
GCL-NT10/60Hxxx (xxx=460-475 in step of 5W)  
GCL-NT10/54Hxxx (xxx=415-430 in step of 5W)  
xxx is standing for rated output power at STC

**Parameters:** Safety Class: Class II  
Max. System Voltage: 1500V DC  
Construction: Framed, with Junction box, cable and connector.

**Tested according to:** IEC 61215-1:2016  
IEC 61215-1-1:2016  
IEC 61215-2:2016  
IEC 61730-1:2016  
IEC 61730-2:2016  
IEC 62716:2013

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704062124017-03

**Date,** 2023-01-11

( Zhulin Zhang )